

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. Memo/School/09/25-26

Dated: 08/06/2025

It is certified that an inspection team headed by Dr. Nivek. Srivastava & team

(Name of Officers with designation) from CMO office J.N.P. PHED inspected

the MSR Bright Future Academy, Jounpur, Kalyanpur, Jounpur (Name & Address

of the school) on 03/06/2025 (date of inspection) and on the basis of Water Test

Report (Attached) bearing no. WTR/JNP/03/2025-26 dated 28/05/2025 of


Water Analysis Report District Jounpur U.P.

(PHED Lab)

certified that

the MSR Bright Future Academy (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till One Year 08/06/2026



[Signature]
अधिसूची अभियन्ता
खण्ड कार्यालय

Signature with Seal: उत्तर प्रदेश जल निगम (ग्रामीण)

Name : जौनपुर

Designation :

Name & Address of the Office / Department :

To The Manager

(Name & Address of the Institution)

MSR Bright Future Academy

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



Water Analysis Report, District-Jaunpur, UTTAR PRADESH

Rept No	319	Date	28/05/2025	Page No	01
---------	-----	------	------------	---------	----

Customer Details

Office Name and Address	MSR BRIGHT FUTURE ACADEMY, TARAPUR, KATGHARA, JAUNPUR, U.P.
Ref Letter No.	WAR/JNP/023/2025-26

Basic details of sample

District	JAUNPUR	Tehsil	SADAR
Gram Panchayat	-	Village	-
Habitation	KATGHARA	Location	TARAPUR, KATGHARA, JAUNPUR, U.P
Water Source	R O Water	Sample No.	Sample 2
Quality of Sample	1000ml (Normal)	Date of S.C.	27/05/2025
Receiving Date	27/05/2025	S. Collector	Mr. MOHIT KUMAR
Sample Depositor	MRS. NEELO JAVED		
Analysis Start Date	27/05/2025	Analysis Completion Date	28/05/2025


Technical Data of Analysis

SR	Analyzed parameters (Unit of Measurement)	Observed Value	Specified Values as per BIS		Ref. Method of Analysis
			Acceptable Limit	Permissible Limit	
1	2	3	4	5	6
1	pH	7.12	6.5-8.5	6.5-8.5	IS 3025 (Part 11): 1983:2021(Electrometric Method)
2	Turbidity (NTU)	0.78	1.00	5.00	IS 3025 (Part 10): 1984:2021(Nephelometer Method)
3	TDS. Mg/1	290	500	2000	IS 3025 (Part 16): 1984:2021(Gravimetric Method)
4	Chloride (as Cl), mg/1	15	250	1000	IS 3025 (Part 32): 1988:2021(Titration Method)
5	Total Alkalinity (as Na ₂ CO ₃), mg/1	220	200	600	IS 3025 (Part 23): 1986:2021(Titration Method)
6	Total Hardness (as CaCO ₃), mg/1	80	200	600	IS 3025 (Part 21): 2009:2021(Titration Method)
7	Calcium (as Ca), mg/1	19.8	75	200	IS 3025 (Part 40): 2019
8	Magnesium (as Mg), mg/1	11.0	30	100	IS 3025 (Part 46): 2019
9	Nitrate (as NO ₃), mg/1	5.5	45	No Relaxation	APHA 23rd Ed 2017, 4500-NO ₃ (B.Ultraviolet Spectrophotometric Screening Method)
10	Fluoride (as F), mg/1	0.274	1.00	1.5	APHA 23rd Ed 2017, 4500-F (C. Ion Selection Electrode Method)
11	Iron (as Fe), mg/1	1.00	1.00	No Relaxation	APHA 23rd Fd 2017, 3500-Fe (B Phenanthroline Method)
12	Residual Chlorine	0.2	NA	0.2	IS 3025 (Part 26): 2021
13	Total Coliform (MPN/100mL)	0	NA	0.0	IS 1622

- Note-**
1. This Certificate refers only to the particular sample(s) submitted for testing.
 2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
 3. The test result reported in this certificate is valid at the time of and under the stated conditions of measurements.
 4. Sample will be stored up to 15 days (in case of non-perishable items only) from the date of issue of tests reports unless otherwise specified.

Prepare by

Lab Technician


Authorized Signatory

Quality/Technical Manager